

Component	Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software®											
	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A	
SYSTEM DATA												
<i>Line 6 Length of main lines, miles</i>	<i>Current condition:</i> Poorly assembled and maintained paper as-built records of existing water main installations makes accurate determination of system pipe length impossible. Length of mains is estimated.	<i>Current condition:</i> Paper records in poor or uncertain condition (no annual tracking of installations & abandonments). Poor procedures to ensure that new water mains installed by developers are accurately documented.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Sound written policy and procedures exist for documenting new water main installations, but gaps in management result in a uncertain degree of error in tabulation of mains length.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Sound written policy and procedures exist for permitting and commissioning new water mains. Highly accurate paper records with regular field validation; or electronic records and asset management system in good condition. Includes system backup.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Sound written policy and procedures exist for permitting and commissioning new water mains. Electronic recordkeeping such as a Geographical Information System (GIS) and asset management system are used to store and manage data.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Sound written policy exists for managing water mains extensions and replacements. Geographic Information System (GIS) data and asset management database agree and random field validation proves truth of databases. Records of annual field validation should be available for review.	Not a choice	
<i>Improvements in quantifying the length of mains</i>	<i>To improve to 1:</i> Assign personnel to inventory current as-built records and compare with customer billing system records and highway plans in order to verify poorly documented pipelines. Assemble policy documents regarding permitting and documentation of water main installations by the utility and building developers; identify gaps in procedures that result in poor documentation of new water main installations.	<i>To improve to 2:</i> Complete inventory of paper records of water main installations for several years prior to audit year. Review policy and procedures for commissioning and documenting new water main installation.		<i>To improve to 3:</i> Finalize updates/improvements to written policy and procedures for permitting/commissioning new main installations. Confirm inventory of records for five years prior to audit year; correct any errors or omissions.		<i>To improve to 4:</i> Launch random field checks of limited number of locations. Convert to electronic database such as a Geographic Information System (GIS) with backup as justified. Develop written policy and procedures.		<i>To improve to 5:</i> Link Geographic Information System (GIS) and asset management databases, conduct field verification of data. Record field verification information at least annually.		<i>To maintain a 5:</i> Continue with standardization and random field validation to improve the completeness and accuracy of the system.	Not a choice	
<i>Line 7b Number of service connections</i>	<i>Current condition:</i> Vague permitting (of new service connections) policy and poor paper recordkeeping of customer connections/billings result in suspect determination of the number of service connections, which may be 10-15% in error from actual count.	<i>Current condition:</i> General permitting policy exists but paper records, procedural gaps, and weak oversight result in questionable total for number of connections, which may vary 5-10% of actual count.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Written account activation policy and procedures exist, but with some gaps in performance and oversight. Computerized information management system is being brought online to replace dated paper recordkeeping system. Reasonably accurate tracking of service connection installations & abandonments; but count can be up to 5% in error from actual total.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Written new account activation and overall billing policies and procedures are adequate and reviewed periodically. Computerized information management system is in use with annual installations & abandonments totaled. Very limited field verifications and audits. Error in count of number of service connections is believed to be no more than 3%.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Policies and procedures for new account activation and overall billing operations are written, well-structured and reviewed at least biannually. Well-managed computerized information management system exists and routine, periodic field checks and internal system audits are conducted. Counts of connections are no more than 2% in error.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Sound written policy and well managed and audited procedures ensure reliable management of service connection population. Computerized information management system, Customer Billing System, and Geographic Information System (GIS) information agree; field validation proves truth of databases. Count of connections recorded as being in error is less than 1% of the entire population.	Not a choice	
<i>Improvements in quantifying the number of retail connections, active and inactive</i>	<i>To improve to 1:</i> Draft new policy and procedures for new account activation and overall billing operations. Research and collect paper records of installations & abandonments for several years prior to audit year.	<i>To improve to 2:</i> Refine policy and procedures for new account activation and overall billing operations. Research computerized recordkeeping system (Customer Information System or Customer Billing System) to improve documentation format for service connections.		<i>To improve to 3:</i> Refine procedures to ensure consistency with new account activation and overall billing policy to establish new service connections or decommission existing connections. Improve process to include all totals for at least five years prior to audit year.		<i>To improve to 4:</i> Formalize regular review of new account activation and overall billing operations policies and procedures. Launch random field checks of limited number of locations. Develop reports and auditing mechanisms for computerized information management system.		<i>To improve to 5:</i> Close any procedural loopholes that allow installations to go undocumented. Link computerized information management system with Geographic Information System (GIS) and formalize field inspection and information system auditing processes. Documentation of new or decommissioned service connections encounters several levels of checks and balances.		<i>To maintain a 5:</i> Continue with standardization and random field validation to improve knowledge of system.	Not a choice	

Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
Component	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
SYSTEM DATA											
<i>Line 10 Average yearly system operating pressure</i>	<p><i>Current condition:</i> Available records are poorly assembled and maintained paper records of supply pump characteristics and water distribution system operating conditions. Average pressure is estimated based upon this information and ground elevations from crude topographical maps. Widely varying distribution system pressures due to undulating terrain, high system head loss and weak/erratic pressure controls further compromise the validity of the average pressure calculation.</p>	<p><i>Current condition:</i> Limited telemetry monitoring of scattered pumping station and water storage tank sites provides some static pressure data, which is recorded in handwritten logbooks. Pressure data is gathered at individual sites only when low pressure complaints arise. Average pressure is determined by averaging relatively crude data, and is affected by significant variation in ground elevations, system head loss and gaps in pressure controls in the distribution system.</p>	<p><i>Conditions between 1 and 2</i></p>	<p><i>Current condition:</i> Effective pressure controls separate different pressure zones; moderate pressure variation across the system, occasional open boundary valves are discovered that breach pressure zones. Basic telemetry monitoring of the distribution system logs pressure data electronically. Pressure data gathered by gauges or dataloggers at fire hydrants or buildings when low pressure complaints arise, and during fire flow tests and system flushing. Reliable topographical data exists. Average pressure is calculated using this mix of data.</p>	<p><i>Conditions between 2 and 3</i></p>	<p><i>Current condition:</i> Reliable pressure controls separate distinct pressure zones; only very occasional open boundary valves are encountered that breach pressure zones. Well-covered telemetry monitoring of the distribution system (not just pumping at source treatment plants or wells) logs extensive pressure data electronically. Pressure gathered by gauges/dataloggers at fire hydrants and buildings when low pressure complaints arise, and during fire flow tests and system flushing. Average pressure is determined by using this mix of reliable data.</p>	<p><i>Conditions between 3 and 4</i></p>	<p><i>Current condition:</i> Well-managed, discrete pressure zones exist with generally predictable pressure fluctuations. A current full-scale SCADA System or similar real-time monitoring system exists to monitor the water distribution system and collect data, including real time pressure readings at representative sites across the system. The average system pressure is determined from reliable monitoring system data.</p>	<p><i>Conditions between 4 and 5</i></p>	<p><i>Current condition:</i> Well-managed pressure districts/zones, SCADA System and hydraulic model exist to give very precise pressure data across the water distribution system. Average system pressure is reliably calculated from extensive, reliable, and cross-checked data. Calculations are reported on an annual basis as a minimum.</p>	Not a choice
<i>Improvements in quantifying the average operating pressure</i>	<p><i>To improve to 1:</i> Employ pressure gauging and/or datalogging equipment to obtain pressure measurements from fire hydrants. Locate accurate topographical maps of service area in order to confirm ground elevations. Research pump data sheets to find pump pressure/flow characteristics.</p>	<p><i>To improve to 2:</i> Formalize a procedure to use pressure gauging/datalogging equipment to gather pressure data during various system events such as low pressure complaints, or operational testing. Gather pump pressure and flow data at different flow regimes. Identify faulty pressure controls (pressure reducing valves, altitude valves, partially open boundary valves) and plan to properly configure pressure zones. Make all pressure data from these efforts available to generate system-wide average pressure.</p>		<p><i>To improve to 3:</i> Expand the use of pressure gauging/datalogging equipment to gather scattered pressure data at a representative set of sites, based upon pressure zones or areas. Utilize pump pressure and flow data to determine supply head entering each pressure zone or district. Correct any faulty pressure controls (pressure reducing valves, altitude valves, and partially open boundary valves) to ensure properly configured pressure zones. Use expanded pressure dataset from these activities to generate system-wide average pressure.</p>		<p><i>To improve to 4:</i> Install a Supervisory Control and Data Acquisition (SCADA) System, or similar real-time monitoring system, to monitor system parameters and control operations. Set regular calibration schedule for instrumentation to insure data accuracy. Obtain accurate topographical data and utilize pressure data gathered from field surveys to provide extensive, reliable data for pressure averaging.</p>		<p><i>To improve to 5:</i> Annually, obtain a system-wide average pressure value from the hydraulic model of the distribution system that has been calibrated via field measurements in the water distribution system and confirmed in comparisons with SCADA System data.</p>		<p><i>To maintain a 5:</i> Continue to refine the hydraulic model of the distribution system and consider linking it with SCADA System for real-time pressure data calibration, and averaging.</p>	Not a choice

Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
Component	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
WATER SUPPLIED											
<i>Line 13 Produced water (volume of treated water entering distribution system from own sources)</i>	<i>Current condition:</i> Less than 25% of water production sources are metered, remaining sources are estimated. No regular meter accuracy testing or electronic calibration conducted.	<i>Current condition:</i> 25% - 50% of treated water production sources are metered; other sources estimated. No regular meter accuracy testing or electronic calibration conducted.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> 50% - 75% of treated water production sources are metered, other sources estimated. Occasional meter accuracy testing or electronic calibration conducted.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> At least 75% of treated water production sources are metered, or at least 90% of the source flow is derived from metered sources. Meter accuracy testing and/or electronic calibration of related instrumentation is conducted annually. Less than 25% of tested meters are found outside of +/- 6% accuracy.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> 100% of treated water production sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> 100% of treated water production sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually, with less than 10% found outside of +/- 3% accuracy. Procedures are reviewed by a third party knowledgeable in the M36 methodology.	Select n/a only if the water utility purchases / imports all of its water resources (i.e. has no sources of its own)
<i>Improvements in quantifying produced water volume</i>	<i>To improve to 1:</i> Organize and launch efforts to collect data for determining volume from own sources.	<i>To improve to 2:</i> Locate all water production sources on maps and in the field, launch meter accuracy testing for existing meters, begin to install meters on unmetered water production sources and replace any obsolete/defective meters.		<i>To improve to 3:</i> Formalize annual meter accuracy testing for all source meters; specify the frequency of testing. Complete installation of meters on unmetered water production sources and complete replacement of all obsolete/defective meters.		<i>To improve to 4:</i> Conduct annual meter accuracy testing and calibration of related instrumentation on all meter installations on a regular basis. Complete project to install new, or replace defective existing, meters so that entire production meter population is metered. Repair or replace meters outside of +/- 6% accuracy.		<i>To improve to 5:</i> Maintain annual meter accuracy testing and calibration of related instrumentation for all meter installations. Repair or replace meters outside of +/- 3% accuracy. Investigate new meter technology; pilot one or more replacements with innovative meters in attempt to further improve meter accuracy.		<i>To maintain a 5:</i> Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Repair or replace meters outside of +/- 3% accuracy. Continually investigate/pilot improving metering technology.	
<i>Line 13a Production meter accuracy</i>	<i>Current condition:</i> Inventory information on meters and paper records of measured volumes exist but are incomplete and/or in a very crude condition; data error cannot be determined.	<i>Current condition:</i> No automatic datalogging of production volumes; daily readings are scribed on paper records without any accountability controls. Flows are not balanced across the water distribution system: tank/storage elevation changes are not employed in calculating the "Volume from own sources" component and archived flow data is adjusted only when grossly evident data error occurs.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Production meter data is logged automatically in electronic format and reviewed at least on a monthly basis with necessary corrections implemented. "Volume from own sources" tabulations include estimate of daily changes in tanks/storage facilities. Meter data is adjusted when gross data errors occur, or occasional meter testing deems this necessary.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Hourly production meter data logged automatically & reviewed on at least a weekly basis. Data is adjusted to correct gross error when meter/instrumentation equipment malfunction is detected; and/or error is confirmed by meter accuracy testing. Tank/storage facility elevation changes are automatically used in calculating a balanced "Volume from own sources" component, and data gaps in the archived data are corrected on at least a weekly basis.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Continuous production meter data is logged automatically & reviewed each business day. Data is adjusted to correct gross error from detected meter/instrumentation equipment malfunction and/or results of meter accuracy testing. Tank/storage facility elevation changes are automatically used in "Volume from own sources" tabulations and data gaps in the archived data are corrected on a daily basis.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Computerized system (SCADA or similar) automatically balances flows from all sources and storages; results are reviewed each business day. Tight accountability controls ensure that all data gaps that occur in the archived flow data are quickly detected and corrected. A regular calibration between SCADA and source meters ensures minimal data transfer error.	Select n/a only if the water utility fails to have meters on its sources of supply AND did not provide a volume for Line 13.

Component	Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A	
WATER SUPPLIED												
<i>Improvements to production meter accuracy</i>	<i>To improve to 1:</i> Develop a plan to restructure recordkeeping system to capture all flow data; set a procedure to review flow data on a daily basis to detect input errors. Obtain more reliable information about existing meters by conducting field inspections of meters and related instrumentation, and obtaining manufacturer literature.	<i>To improve to 2:</i> Install automatic datalogging equipment on production meters. Complete installation of level instrumentation at all tanks/storage facilities and include tank level data in automatic calculation routine in a computerized system. Construct a computerized listing or spreadsheet to archive input volumes, tank/storage volume changes and import/export flows in order to determine the composite "Water Supplied" volume for the distribution system. Set a procedure to review this data on a monthly basis to detect gross anomalies and data gaps.		<i>To improve to 3:</i> Refine computerized data collection and archive to include hourly production meter data that is reviewed at least on a weekly basis to detect specific data anomalies and gaps. Use daily net storage change to balance flows in calculating "Water Supplied" volume. Necessary corrections to data errors are implemented on a weekly basis.		<i>To improve to 4:</i> Ensure that all flow data is collected and archived on at least an hourly basis. All data is reviewed and detected errors corrected each business day. Tank/storage levels variations are employed in calculating balanced "Water Supplied" component. Adjust production meter data for gross error and inaccuracy confirmed by testing.		<i>To improve to 5:</i> Link all production and tank/storage facility elevation change data to a Supervisory Control & Data Acquisition (SCADA) System, or similar computerized monitoring/control system, and establish automatic flow balancing algorithm and regularly calibrate between SCADA and source meters. Data is reviewed and corrected each business day.		<i>To maintain a 5:</i> Monitor meter innovations for development of more accurate and less expensive flowmeters. Continue to replace or repair meters as they perform outside of desired accuracy limits. Stay abreast of new and more accurate water level instruments to better record tank/storage levels and archive the variations in storage volume. Keep current with SCADA and data management systems to ensure that archived data is well-managed and error free.		
<i>Line 14 Total treated water purchased</i> <i>Volume for Line 14 is populated from the Water Use Survey</i>	<i>Current condition:</i> Less than 25% of imported water sources are metered, remaining sources are estimated. No regular meter accuracy testing.	<i>Current condition:</i> 25% - 50% of imported water sources are metered; other sources estimated. No regular meter accuracy testing.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> 50% - 75% of imported water sources are metered, other sources estimated. Occasional meter accuracy testing conducted.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> At least 75% of imported water sources are metered, meter accuracy testing and/or electronic calibration of related instrumentation is conducted annually for all meter installations. Less than 25% of tested meters are found outside of +/- 6% accuracy.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> 100% of imported water sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> 100% of imported water sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually for all meter installations, with less than 10% of accuracy tests found outside of +/- 3% accuracy.	Select n/a if the water utility's supply is exclusively from its own water resources (no bulk purchased/imported water)	
<i>Improvements in quantifying volume of treated water purchased</i>	<i>To improve to 1:</i> Review bulk water purchase agreements with partner suppliers; confirm requirements for use and maintenance of accurate metering. Identify needs for new or replacement meters with goal to meter all imported water sources.	<i>To improve to 2:</i> Locate all imported water sources on maps and in the field, launch meter accuracy testing for existing meters, begin to install meters on unmetered imported water interconnections and replace obsolete/defective meters.		<i>To improve to 3:</i> Formalize annual meter accuracy testing for all imported water meters, planning for both regular meter accuracy testing and calibration of the related instrumentation. Continue installation of meters on unmetered imported water interconnections and replacement of obsolete/defective meters.		<i>To improve to 4:</i> Complete project to install new, or replace defective, meters on all imported water interconnections. Maintain annual meter accuracy testing for all imported water meters and conduct calibration of related instrumentation at least annually. Repair or replace meters outside of +/- 6% accuracy.		<i>To improve to 5:</i> Conduct meter accuracy testing for all meters on a semi-annual basis, along with calibration of all related instrumentation. Repair or replace meters outside of +/- 3% accuracy. Investigate new meter technology; pilot one or more replacements with innovative meters in attempt to improve meter accuracy.		<i>To maintain a 5:</i> Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Continue to conduct calibration of related instrumentation on a semi-annual basis. Repair or replace meters outside of +/- 3% accuracy. Continually investigate/pilot improving metering technology.		

Component	Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A	
WATER SUPPLIED												
<i>Line 14a Treated purchased water meter accuracy</i>	<i>Current condition:</i> Inventory information on imported meters and paper records of measured volumes exist but are incomplete and/or in a very crude condition; data error cannot be determined. Written agreement(s) with water Exporter(s) are missing or written in vague language concerning meter management and testing.	<i>Current condition:</i> No automatic datalogging of imported supply volumes; daily readings are scribed on paper records without any accountability controls to confirm data accuracy and the absence of errors and data gaps in recorded volumes. Written agreement requires meter accuracy testing but is vague on the details of how and who conducts the testing.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Imported supply metered flow data is logged automatically in electronic format and reviewed at least on a monthly basis by the Exporter with necessary corrections implemented. Meter data is adjusted by the Exporter when gross data errors are detected. A coherent data trail exists for this process to protect both the selling and the purchasing Utility. Written agreement exists and clearly states requirements and roles for meter accuracy testing and data management.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Hourly Imported supply metered data is logged automatically & reviewed on at least a weekly basis by the Exporter. Data is adjusted to correct gross error when meter/instrumentation equipment malfunction is detected; and to correct for error confirmed by meter accuracy testing. Any data gaps in the archived data are detected and corrected during the weekly review. A coherent data trail exists for this process to protect both the selling and the purchasing Utility.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Continuous Imported supply metered flow data is logged automatically & reviewed each business day by the Exporter. Data is adjusted to correct gross error from detected meter/instrumentation equipment malfunction and/or results of meter accuracy testing. Any data errors/gaps are detected and corrected on a daily basis. A data trail exists for the process to protect both the selling and the purchasing Utility.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Computerized system (SCADA or similar) automatically records data which is reviewed each business day by the Exporter. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling and purchasing Utility at least once every five years.	Select n/a if the Imported water supply is unmetered, with Imported water quantities estimated on the billing invoices sent by the Exporter to the purchasing Utility AND did not provide a volume for Line 14.	
<i>Improvements to treated purchased water meter accuracy</i>	<i>To improve to 1:</i> Develop a plan to restructure recordkeeping system to capture all flow data; set a procedure to review flow data on a daily basis to detect input errors. Obtain more reliable information about existing meters by conducting field inspections of meters and related instrumentation, and obtaining manufacturer literature. Review the written agreement between the selling and purchasing Utility.	<i>To improve to 2:</i> Install automatic datalogging equipment on imported supply meters. Set a procedure to review this data on a monthly basis to detect gross anomalies and data gaps. Launch discussions with the Exporters to jointly review terms of the written agreements regarding meter accuracy testing and data management; revise the terms as necessary.	<i>To improve to 3:</i> Refine computerized data collection and archive to include hourly imported supply metered flow data that is reviewed at least on a weekly basis to detect specific data anomalies and gaps. Make necessary corrections to errors/data errors on a weekly basis.	<i>To improve to 4:</i> Ensure that all Imported supply metered flow data is collected and archived on at least an hourly basis. All data is reviewed and errors/data gaps are corrected each business day.	<i>To improve to 5:</i> Conduct accountability checks to confirm that all Imported supply metered data is reviewed and corrected each business day by the Exporter. Results of all meter accuracy tests and data corrections should be available for sharing between the Exporter and the purchasing Utility. Establish a schedule for a regular review and updating of the contractual language in the written agreement between the selling and the purchasing Utility; at least every five years.	<i>To maintain a 5:</i> Monitor meter innovations for development of more accurate and less expensive flowmeters; work with the Exporter to help identify meter replacement needs. Keep communication lines with Exporters open and maintain productive relations. Keep the written agreement current with clear and explicit language that meets the ongoing needs of all parties.						
<i>Line 15 Total treated wholesale water sales Volume for Line 15 is populated from the Water Use Survey</i>	<i>Current condition:</i> Less than 25% of exported water sources are metered, remaining sources are estimated. No regular meter accuracy testing.	<i>Current condition:</i> 25% - 50% of exported water sources are metered; other sources estimated. No regular meter accuracy testing.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> 50% - 75% of exported water sources are metered, other sources estimated. Occasional meter accuracy testing conducted.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> At least 75% of exported water sources are metered, meter accuracy testing and/or electronic calibration conducted annually. Less than 25% of tested meters are found outside of +/- 6% accuracy.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> 100% of exported water sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> 100% of exported water sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually for all meter installations, with less than 10% of accuracy tests found outside of +/- 3% accuracy.	Select n/a if the water utility sells no bulk water to neighboring water utilities (no exported water sales)	

Component	Assessment Scale Table										
	Adapted from American Water Works Association Free Water Audit Software©										
WATER SUPPLIED	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
<i>Improvements in quantifying volume of treated wholesale water sales</i>	<i>To improve to 1:</i> Review bulk water sales agreements with purchasing utilities; confirm requirements for use & upkeep of accurate metering. Identify needs to install new, or replace defective meters as needed.	<i>To improve to 2:</i> Locate all exported water sources on maps and in field, launch meter accuracy testing for existing meters, begin to install meters on unmetered exported water interconnections and replace obsolete/defective meters.		<i>To improve to 3:</i> Formalize annual meter accuracy testing for all exported water meters. Continue installation of meters on unmetered exported water interconnections and replacement of obsolete/defective meters.		<i>To improve to 4:</i> Complete project to install new, or replace defective, meters on all exported water interconnections. Maintain annual meter accuracy testing for all exported water meters. Repair or replace meters outside of +/- 6% accuracy.		<i>To improve to 5:</i> Maintain annual meter accuracy testing for all meters. Repair or replace meters outside of +/- 3% accuracy. Investigate new meter technology; pilot one or more replacements with innovative meters in attempt to improve meter accuracy.		<i>To maintain a 5:</i> Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Repair or replace meters outside of +/- 3% accuracy. Continually investigate/pilot improving metering technology.	
<i>Line 15a Treated wholesale water meter accuracy</i>	<i>Current condition:</i> Inventory information on exported meters and paper records of measured volumes exist but are incomplete and/or in a very crude condition; data error cannot be determined. Written agreement(s) with the utility purchasing the water are missing or written in vague language concerning meter management and testing.	<i>Current condition:</i> No automatic datalogging of exported supply volumes; daily readings are scribed on paper records without any accountability controls to confirm data accuracy and the absence of errors and data gaps in recorded volumes. Written agreement requires meter accuracy testing but is vague on the details of how and who conducts the testing.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Exported metered flow data is logged automatically in electronic format and reviewed at least on a monthly basis, with necessary corrections implemented. Meter data is adjusted by the utility selling (exporting) the water when gross data errors are detected. A coherent data trail exists for this process to protect both the utility exporting the water and the purchasing Utility. Written agreement exists and clearly states requirements and roles for meter accuracy testing and data management.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Hourly exported supply metered data is logged automatically & reviewed on at least a weekly basis by the utility selling the water. Data is adjusted to correct gross error when meter/instrumentation equipment malfunction is detected; and to correct for error found by meter accuracy testing. Any data gaps in the archived data are detected and corrected during the weekly review. A coherent data trail exists for this process to protect both the selling (exporting) utility and the purchasing Utility.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Continuous exported supply metered flow data is logged automatically & reviewed each business day by the utility selling (exporting) the water. Data is adjusted to correct gross error from detected meter/instrumentation equipment malfunction and any error confirmed by meter accuracy testing. Any data errors/gaps are detected and corrected on a daily basis. A data trail exists for the process to protect both the selling (exporting) Utility and the purchasing Utility.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Computerized system (SCADA or similar) automatically records data which is reviewed each business day by the utility selling (exporting) the water. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling Utility and purchasing Utility at least once every five years.	Select n/a only if the water utility fails to have meters on its exported supply interconnections AND did not provide a volume for Line 15.
<i>Improvements to treated wholesale water meter accuracy</i>	<i>To improve to 1:</i> Develop a plan to restructure recordkeeping system to capture all flow data; set a procedure to review flow data on a daily basis to detect input errors. Obtain more reliable information about existing meters by conducting field inspections of meters and related instrumentation, and obtaining manufacturer literature. Review the written agreement between the utility selling (exporting) the water and the purchasing Utility.	<i>To improve to 2:</i> Install automatic datalogging equipment on exported supply meters. Set a procedure to review this data on a monthly basis to detect gross anomalies and data gaps. Launch discussions with the purchasing utilities to jointly review terms of the written agreements regarding meter accuracy testing and data management; revise the terms as necessary.		<i>To improve to 3:</i> Refine computerized data collection and archive to include hourly exported supply metered flow data that is reviewed at least on a weekly basis to detect specific data anomalies and gaps. Make necessary corrections to errors/data errors on a weekly basis.		<i>To improve to 4:</i> Ensure that all exported metered flow data is collected and archived on at least an hourly basis. All data is reviewed and errors/data gaps are corrected each business day.		<i>To improve to 5:</i> Conduct accountability checks to confirm that all exported metered flow data is reviewed and corrected each business day by the utility selling the water. Results of all meter accuracy tests and data corrections should be available for sharing between the utility and the purchasing Utility. Establish a schedule for a regular review and updating of the contractual language in the written agreements with the purchasing utilities; at least every five years.		<i>To maintain a 5:</i> Monitor meter innovations for development of more accurate and less expensive flowmeters; work with the purchasing utilities to help identify meter replacement needs. Keep communication lines with the purchasing utilities open and maintain productive relations. Keep the written agreement current with clear and explicit language that meets the ongoing needs of all parties.	

Component	Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software®											
	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A	
AUTHORIZED CONSUMPTION												
Line 17 Billed metered Volume for Line 17 is populated from the Water Use Survey	<p><i>Current condition:</i> Less than 50% of customers with volume-based billings from meter readings; flat or fixed rate billing exist for the majority of the customer population.</p>	<p><i>Current condition:</i> At least 50% of customers with volume-based billing from meter reads; flat rate billing for others. Manual meter reading is conducted, with less than 50% meter read success rate, remaining accounts' consumption is estimated. Limited meter records, no regular meter testing or replacement. Billing data maintained on paper records, with no auditing.</p>	<p><i>Conditions between 1 and 2</i></p>	<p><i>Current condition:</i> At least 75% of customers with volume-based, billing from meter reads; flat or fixed rate billing for remaining accounts. Manual meter reading is conducted with at least 50% meter read success rate; consumption for accounts with failed reads is estimated. Purchase records verify age of customer meters; only very limited meter accuracy testing is conducted. Customer meters are replaced only upon complete failure. Computerized billing records exist, but only sporadic internal auditing conducted.</p>	<p><i>Conditions between 2 and 3</i></p>	<p><i>Current condition:</i> At least 90% of customers with volume-based billing from meter reads; consumption for remaining accounts is estimated. Manual customer meter reading gives at least 80% customer meter reading success rate; consumption for accounts with failed reads is estimated. Good customer meter records exist, but only limited meter accuracy testing is conducted. Regular replacement is conducted for the oldest meters. Computerized billing records exist with annual auditing of summary statistics conducting by utility personnel.</p>	<p><i>Conditions between 3 and 4</i></p>	<p><i>Current condition:</i> At least 97% of customers exist with volume-based billing from meter reads. At least 90% customer meter reading success rate; or at least 80% read success rate with planning and budgeting for trials of Automatic Meter Reading (AMR) or Advanced Metering Infrastructure (AMI) in one or more pilot areas. Good customer meter records. Regular meter accuracy testing guides replacement of statistically significant number of meters each year. Routine auditing of computerized billing records for global and detailed statistics occurs annually by utility personnel, and is verified by third party at least once every five years.</p>	<p><i>Conditions between 4 and 5</i></p>	<p><i>Current condition:</i> At least 99% of customers exist with volume-based billing from meter reads. At least 95% customer meter reading success rate; or minimum 80% meter reading success rate, with Automatic Meter Reading (AMR) or Advanced Metering Infrastructure (AMI) trials underway. Statistically significant customer meter testing and replacement program in place on a continuous basis. Computerized billing with routine, detailed auditing, including field investigation of representative sample of accounts undertaken annually by utility personnel. Audit is conducted by third party auditors at least once every three years.</p>	Not a choice	
Improvements in quantifying volume of billed metered consumption	<p><i>To improve to 1:</i> Conduct investigations or trials of customer meters to select appropriate meter models. Budget funding for meter installations. Investigate volume based water rate structures.</p>	<p><i>To improve to 2:</i> Purchase and install meters on unmetered accounts. Implement policies to improve meter reading success. Catalog meter information during meter read visits to identify age/model of existing meters. Test a minimal number of meters for accuracy. Install computerized billing system.</p>	<p><i>To improve to 3:</i> Purchase and install meters on unmetered accounts. Eliminate flat fee billing and establish appropriate water rate structure based upon measured consumption. Continue to achieve verifiable success in removing manual meter reading barriers. Expand meter accuracy testing. Launch regular meter replacement program. Launch a program of annual auditing of global billing statistics by utility personnel.</p>	<p><i>To improve to 4:</i> Purchase and install meters on unmetered accounts. If customer meter reading success rate is less than 97%, assess cost-effectiveness of Automatic Meter Reading (AMR) or Advanced Metering Infrastructure (AMI) system for portion or entire system; or otherwise achieve ongoing improvements in manual meter reading success rate to 97% or higher. Refine meter accuracy testing program. Set meter replacement goals based upon accuracy test results. Implement annual auditing of detailed billing records by utility personnel and implement third party auditing at least once every five years.</p>	<p><i>To improve to 5:</i> Purchase and install meters on unmetered accounts. Launch Automatic Meter Reading (AMR) or Advanced Metering Infrastructure (AMI) system trials if manual meter reading success rate of at least 99% is not achieved within a five-year program. Continue meter accuracy testing program. Conduct planning and budgeting for large scale meter replacement based upon meter life cycle analysis using cumulative flow target. Continue annual detailed billing data auditing by utility personnel and conduct third party auditing at least once every three years.</p>	<p><i>To maintain a 5:</i> Continue annual internal billing data auditing, and third party auditing at least every three years. Continue customer meter accuracy testing to ensure that accurate customer meter readings are obtained and entered as the basis for volume based billing. Stay abreast of improvements in Automatic Meter Reading (AMR) and Advanced Metering Infrastructure (AMI) and information management. Plan and budget for justified upgrades in metering, meter reading and billing data management to maintain very high accuracy in customer metering and billing.</p>	Not a choice					

Component	Assessment Scale Table										
	Adapted from American Water Works Association Free Water Audit Software©										
AUTHORIZED CONSUMPTION	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
<i>Line 18 Billed unmetered</i>	<p><i>Current condition:</i> Water utility policy does not require customer metering; flat or fixed fee billing is employed. No data is collected on customer consumption. The only estimates of customer population consumption available are derived from data estimation methods using average fixture count multiplied by number of connections, or similar approach.</p>	<p><i>Current condition:</i> Water utility policy does not require customer metering; flat or fixed fee billing is employed. Some metered accounts exist in parts of the system (pilot areas or District Metered Areas) with consumption read periodically or recorded on portable dataloggers over one, three, or seven day periods. Data from these sample meters are used to infer consumption for the total customer population. Site specific estimation methods are used for unusual buildings/water uses.</p>	<p><i>Conditions between 1 and 2</i></p>	<p><i>Current condition:</i> Water utility policy does require metering and volume based billing in general. However, a liberal amount of exemptions and a lack of clearly written and communicated procedures result in up to 20% of billed accounts believed to be unmetered by exemption; or the water utility is in transition to becoming fully metered, and a large number of customers remain unmetered. A rough estimate of the annual consumption for all unmetered accounts is included in the annual water audit, with no inspection of individual unmetered accounts.</p>	<p><i>Conditions between 2 and 3</i></p>	<p><i>Current condition:</i> Water utility policy does require metering and volume based billing but established exemptions exist for a portion of accounts such as municipal buildings. As many as 15% of billed accounts are unmetered due to this exemption or meter installation difficulties. Only a group estimate of annual consumption for all unmetered accounts is included in the annual water audit, with no inspection of individual unmetered accounts.</p>	<p><i>Conditions between 3 and 4</i></p>	<p><i>Current condition:</i> Water utility policy does require metering and volume based billing for all customer accounts. However, less than 5% of billed accounts remain unmetered because meter installation is hindered by unusual circumstances. The goal is to minimize the number of unmetered accounts. Reliable estimates of consumption are obtained for these unmetered accounts via site specific estimation methods.</p>	<p><i>Conditions between 4 and 5</i></p>	<p><i>Current condition:</i> Water utility policy does require metering and volume based billing for all customer accounts. Less than 2% of billed accounts are unmetered and exist because meter installation is hindered by unusual circumstances. The goal exists to minimize the number of unmetered accounts to the extent that is economical. Reliable estimates of consumption are obtained at these accounts via site specific estimation methods. OR Select 5 if it is the policy of the water utility to meter all customer connections and it has been confirmed by detailed auditing that all customers do indeed have a water meter; i.e. no intentionally unmetered accounts exist.</p>	Not a choice
<i>Improvements in quantifying volume of billed unmetered consumption</i>	<p><i>To improve to 1:</i> Conduct research and evaluate cost/benefit of a new water utility policy to require metering of the customer population; thereby greatly reducing or eliminating unmetered accounts. Conduct pilot metering project by installing water meters in small sample of customer accounts and periodically reading the meters or datalogging the water consumption over one, three, or seven day periods.</p>	<p><i>To improve to 2:</i> Implement a new water utility policy requiring customer metering. Launch or expand pilot metering study to include several different meter types, which will provide data for economic assessment of full scale metering options. Assess sites with access difficulties to devise means to obtain water consumption volumes. Begin customer meter installation.</p>	<p><i>To improve to 3:</i> Refine policy and procedures to improve customer metering participation for all but solidly exempt accounts. Assign staff resources to review billing records to identify errant unmetered properties. Specify metering needs and funding requirements to install sufficient meters to significant reduce the number of unmetered accounts.</p>	<p><i>To improve to 4:</i> Push to install customer meters on a full scale basis. Refine metering policy and procedures to ensure that all accounts, including municipal properties, are designated for meters. Plan special efforts to address "hard-to-access" accounts. Implement procedures to obtain a reliable consumption estimate for the remaining few unmetered accounts awaiting meter installation.</p>	<p><i>To improve to 5:</i> Continue customer meter installation throughout the service area, with a goal to minimize unmetered accounts. Sustain the effort to investigate accounts with access difficulties, and devise means to install water meters or otherwise measure water consumption.</p>	<p><i>To maintain a 5:</i> Continue to refine estimation methods for unmetered consumption and explore means to establish metering, for as many billed remaining unmetered accounts as is economically feasible.</p>	Not a choice				

Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
Component	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
AUTHORIZED CONSUMPTION											
<i>Line 19 Unbilled metered</i>	<p><i>Current condition:</i> Billing practices exempt certain accounts, such as municipal buildings, but written policies do not exist; and a reliable count of unbilled metered accounts is unavailable. Meter upkeep and meter reading on these accounts is rare and not considered a priority. Due to poor recordkeeping and lack of auditing, water consumption for all such accounts is purely estimated.</p>	<p><i>Current condition:</i> Billing practices exempt certain accounts, such as municipal buildings, but only scattered, dated written directives exist to justify this practice. A reliable count of unbilled metered accounts is unavailable. Sporadic meter replacement and meter reading occurs on an as-needed basis. The total annual water consumption for all unbilled, metered accounts is estimated based upon approximating the number of accounts and assigning consumption from actively billed accounts of same meter size.</p>	<p><i>Conditions between 1 and 2</i></p>	<p><i>Current condition:</i> Dated written procedures permit billing exemption for specific accounts, such as municipal properties, but are unclear regarding certain other types of accounts. Meter reading is given low priority and is sporadic. Consumption is quantified from meter readings where available. The total number of unbilled, unmetered accounts must be estimated along with consumption volumes.</p>	<p><i>Conditions between 2 and 3</i></p>	<p><i>Current condition:</i> Written policies regarding billing exemptions exist but adherence in practice is questionable. Metering and meter reading for municipal buildings is reliable but sporadic for other unbilled metered accounts. Periodic auditing of such accounts is conducted. Water consumption is quantified directly from meter readings where available, but the majority of the consumption is estimated.</p>	<p><i>Conditions between 3 and 4</i></p>	<p><i>Current condition:</i> Written policy identifies the types of accounts granted a billing exemption. Customer meter management and meter reading are considered secondary priorities, but meter reading is conducted at least annually to obtain consumption volumes for the annual water audit. High level auditing of billing records ensures that a reliable census of such accounts exists.</p>	<p><i>Conditions between 4 and 5</i></p>	<p><i>Current condition:</i> Clearly written policy identifies the types of accounts given a billing exemption, with emphasis on keeping such accounts to a minimum. Customer meter management and meter reading for these accounts is given proper priority and is reliably conducted. Regular auditing confirms this. Total water consumption for these accounts is taken from reliable readings from accurate meters. OR Select 5 if all billing-exempt consumption is unmetered.</p>	Not a choice
<i>Improvements in quantifying volume of unbilled metered consumption</i>	<p><i>To improve to 1:</i> Reassess the water utility's policy allowing certain accounts to be granted a billing exemption. Draft an outline of a new written policy for billing exemptions, with clear justification as to why any accounts should be exempt from billing, and with the intention to keep the number of such accounts to a minimum.</p>	<p><i>To improve to 2:</i> Review historic written directives and policy documents allowing certain accounts to be billing-exempt. Draft an outline of a written policy for billing exemptions; identify a criterion that grants an exemption, with a goal of keeping this number of accounts to a minimum. Consider increasing the priority of reading meters on unbilled accounts at least annually.</p>		<p><i>To improve to 3:</i> Draft a new written policy regarding billing exemptions based upon consensus criteria allowing this occurrence. Assign resources to audit meter records and billing records to obtain census of unbilled metered accounts. Gradually include a greater number of these metered accounts to the routes for regular meter reading.</p>		<p><i>To improve to 4:</i> Communicate billing exemption policy throughout the organization and implement procedures that ensure proper account management. Conduct inspections of accounts confirmed in unbilled metered status and verify that accurate meters exist and are scheduled for routine meter readings. Gradually increase the number of unbilled metered accounts that are included in regular meter reading routes.</p>		<p><i>To improve to 5:</i> Ensure that meter management (meter accuracy testing, meter replacement) and meter reading activities for unbilled accounts are accorded the same priority as billed accounts. Establish ongoing annual auditing process to ensure that water consumption is reliably collected and provided to the annual water audit process.</p>		<p><i>To maintain a 5:</i> Reassess the utility's philosophy in allowing any water uses to go "unbilled". It is possible to meter and bill all accounts; even if the fee charged for water consumption is discounted or waived. Metering and billing all accounts ensures that water consumption is tracked and water waste from plumbing leaks is detected and minimized.</p>	Not a choice

Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
Component	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
AUTHORIZED CONSUMPTION											
<i>Line 20 Unbilled unmetered</i>	<i>Current condition:</i> Extent of unbilled, unmetered consumption is unknown due to unclear policies and poor recordkeeping. Total consumption is quantified based upon a purely subjective estimate.	<i>Current condition:</i> Clear extent of unbilled, unmetered consumption is unknown, but a number of events are randomly documented each year, confirming existence of such consumption, but without sufficient documentation to quantify an accurate estimate of the annual volume consumed.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Extent of unbilled, unmetered consumption is partially known, and procedures exist to document certain events such as miscellaneous fire hydrant uses. Formulae are used to quantify the consumption from such events (time running multiplied by typical flowrate, multiplied by number of events).	Default value of 0.25% of volume of billed authorized water is employed.	<i>Current condition:</i> Coherent policies exist for some forms of unbilled, unmetered consumption but others await closer evaluation. Reasonable recordkeeping for the managed uses exists and allows for annual volumes to be quantified by inference, but unsupervised uses are estimated.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Clear policies and good recordkeeping exist for some uses (ex: water used in periodic testing of unmetered fire connections), but other uses (ex: miscellaneous uses of fire hydrants) have limited oversight. Total consumption is a mix of well quantified use such as from formulae (time running multiplied by typical flow, multiplied by number of events) or temporary meters, and relatively subjective estimates of less regulated use.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Clear policies exist to identify permitted use of water in unbilled, unmetered fashion, with the intention of minimizing this type of consumption. Good records document each occurrence and consumption is quantified via formulae (time running multiplied by typical flow, multiplied by number of events) or use of temporary meters.	Not a choice
<i>Improvements in quantifying volume of unbilled unmetered consumption</i>	<i>To improve to 2.5:</i> Utilize the accepted default value of 0.25% of billed authorized as an expedient means to gain a reasonable quantification of this use. <i>To improve to 1:</i> Establish a policy regarding what water uses should be allowed to remain as unbilled and unmetered. Consider tracking a small sample of one such use (ex: fire hydrant flushings).	<i>To improve to 2.5:</i> Utilize the accepted default value of 0.25% of billed authorized as an expedient means to gain a reasonable quantification of this use. <i>To improve to 2:</i> Evaluate the documentation of events that have been observed. Meet with user groups (ex: for fire hydrants - fire departments, contractors to ascertain their need and/or volume requirements for water from fire hydrants).	<i>To improve to 2.5:</i> Utilize accepted default value of 0.25% of billed authorized as an expedient means to gain a reasonable quantification of all such use. This is particularly appropriate for water utilities that are in the early stages of the water auditing process, and should focus on other components since the volume of unbilled, unmetered consumption is usually a relatively small quantity component, and other larger-quantity components should take priority.	<i>To improve to 3:</i> Finalize policy and begin to conduct field checks to better establish and quantify such usage. Proceed if top-down audit exists and/or a great volume of such use is suspected.	<i>To improve to 4:</i> Assess water utility policy and procedures for various unmetered usages. For example, ensure that a policy exists and permits are issued for use of fire hydrants by persons outside of the utility. Create written procedures for use and documentation of fire hydrants by water utility personnel. Use same approach for other types of unbilled, unmetered water usage.	<i>To improve to 5:</i> Refine written procedures to ensure that all uses of unbilled, unmetered water are overseen by a structured permitting process managed by water utility personnel. Reassess policy to determine if some of these uses have value in being converted to billed and/or metered status.	<i>To maintain a 5:</i> Continue to refine policy and procedures with intention of reducing the number of allowable uses of water in unbilled and unmetered fashion. Any uses that can feasibly become billed and metered should be converted eventually.	Not a choice			

Component	Assessment Scale Table										
	Adapted from American Water Works Association Free Water Audit Software©										
APPARENT LOSSES	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
<i>Line 23 Average customer meter accuracy</i>	<i>Current condition:</i> Customer meters exist, but with unorganized paper records on meters; no meter accuracy testing or meter replacement program for any size of retail meter. Metering workflow is driven chaotically with no proactive management. Loss volume due to aggregate meter inaccuracy is estimated.	<i>Current condition:</i> Poor recordkeeping and meter oversight is recognized by water utility management who has allotted staff and funding resources to organize improved recordkeeping and start meter accuracy testing. Existing paper records gathered and organized to provide cursory disposition of meter population. Customer meters are tested for accuracy only upon customer request.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Reliable recordkeeping exists; meter information is improving as meters are replaced. Meter accuracy testing is conducted annually for a small number of meters (more than just customer requests, but less than 1% of inventory). A limited number of the oldest meters are replaced each year. Inaccuracy volume is largely an estimate, but refined based upon limited testing data.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> A reliable electronic recordkeeping system for meters exists. The meter population includes a mix of new high performing meters and dated meters with suspect accuracy. Routine, but limited, meter accuracy testing and meter replacement occur. Inaccuracy volume is quantified using a mix of reliable and less certain data.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Ongoing meter replacement and accuracy testing result in highly accurate customer meter population. Testing is conducted on samples of meters of varying age and accumulated volume of throughput to determine optimum replacement time for various types of meters.	<i>Current condition:</i> Ongoing meter replacement and accuracy testing result in highly accurate customer meter population. Statistically significant numbers of meters are tested in audit year. This testing is conducted on samples of meters of varying age and accumulated volume of throughput to determine optimum replacement time for these meters.	<i>Current condition:</i> Good records of all active customer meters exist and include as a minimum: meter number, account number/location, type, size and manufacturer. Ongoing meter replacement occurs according to a targeted and justified basis. Regular meter accuracy testing gives a reliable measure of composite inaccuracy volume for the customer meter population. New metering technology is embraced to keep overall accuracy improving. Procedures are reviewed by a third party knowledgeable in the M36 methodology.	Not a choice
<i>Improvements to average customer meter accuracy</i>	<i>To improve to 1:</i> Gather available meter purchase records. Conduct testing on a small number of meters believed to be the most inaccurate. Review staffing needs of the metering group and budget for necessary resources to better organize meter management.	<i>To improve to 2:</i> Implement a reliable record keeping system for customer meter histories, preferably using electronic methods typically linked to, or part of, the Customer Billing System or Customer Information System. Expand meter accuracy testing to a larger group of meters.	<i>To improve to 3:</i> Standardize the procedures for meter recordkeeping within an electronic information system. Accelerate meter accuracy testing and meter replacements guided by testing results.	<i>To improve to 4:</i> Expand annual meter accuracy testing to evaluate a statistically significant number of meter makes/models. Expand meter replacement program to replace statistically significant number of poor performing meters each year.	<i>To improve to 4.5:</i> Continue efforts to manage meter population with reliable recordkeeping. Test a statistically significant number of meters each year and analyze test results in an ongoing manner to serve as a basis for a target meter replacement strategy based upon accumulated volume throughput.	<i>To improve to 5:</i> Continue efforts to manage meter population with reliable recordkeeping, meter testing and replacement. Evaluate new meter types and install one or more types in 5-10 customer accounts each year in order to pilot improving metering technology.	<i>To maintain a 5:</i> Increase the number of meters tested and replaced as justified by meter accuracy test data. Continually monitor development of new metering technology and Advanced Metering Infrastructure (AMI) to grasp opportunities for greater accuracy in metering of water flow and management of customer consumption data.	Not a choice			

Component	Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A	
APPARENT LOSSES												
Line 25 Systematic data handling discrepancy	<p><i>Current condition:</i> Policies and procedures for activation of new customer water billing accounts are vague and lack accountability. Billing data is maintained on paper records which are not well organized. No auditing is conducted to confirm billing data handling efficiency. An unknown number of customers escape routine billing due to lack of billing process oversight.</p>	<p><i>Current condition:</i> Policy and procedures for activation of new customer accounts and oversight of billing records exist but need refinement. Billing data is maintained on paper records or insufficiently capable electronic database. Only periodic unstructured auditing work is conducted to confirm billing data handling efficiency. The volume of unbilled water due to billing lapses is a guess.</p>	<p><i>Conditions between 1 and 2</i></p>	<p><i>Current condition:</i> Policy and procedures for new account activation and oversight of billing operations exist but needs refinement. Computerized billing system exists, but is dated or lacks needed functionality. Periodic, limited internal audits conducted and confirm with approximate accuracy the consumption volumes lost to billing lapses.</p>	<p>Default value of 0.25% of volume of billed authorized water is employed.</p>	<p><i>Current condition:</i> Policy and procedures for new account activation and oversight of billing operations is adequate and reviewed periodically. Computerized billing system is in use with basic reporting available. Any effect of billing adjustments on measured consumption volumes is well understood. Internal checks of billing data error conducted annually. Reasonably accurate quantification of consumption volume lost to billing lapses is obtained.</p>	<p><i>Conditions between 3 and 4</i></p>	<p><i>Current condition:</i> New account activation and billing operations policy and procedures are reviewed at least biannually. Computerized billing system includes an array of reports to confirm billing data and system functionality. Checks are conducted routinely to flag and explain zero consumption accounts. Annual internal checks conducted with third party audit conducted at least once every five years. Accountability checks flag billing lapses. Consumption lost to billing lapses is well quantified and reducing year-by-year.</p>	<p><i>Conditions between 4 and 5</i></p>	<p><i>Current condition:</i> Sound written policy and procedures exist for new account activation and oversight of customer billing operations. Robust computerized billing system gives high functionality and reporting capabilities which are utilized, analyzed and the results reported each billing cycle. Assessment of policy and data handling errors are conducted internally and audited by third party at least once every three years, ensuring consumption lost to billing lapses is minimized and detected as it occurs.</p>	Not a choice	
Improvements in quantifying loss due to systematic data handling error	<p><i>To improve to 1:</i> Draft written policy and procedures for activating new water billing accounts and oversight of billing operations. Investigate and budget for computerized customer billing system. Conduct initial audit of billing records by flow-charting the basic business processes of the customer account/billing function.</p>	<p><i>To improve to 2.5:</i> Use accepted default of 0.25% of billed authorized. <i>To improve to 2:</i> Finalize written policy and procedures for activation of new billing accounts and overall billing operations management. Implement a computerized customer billing system. Conduct initial audit of billing records as part of this process.</p>		<p><i>To improve to 3:</i> Refine new account activation and billing operations procedures and ensure consistency with the utility policy regarding billing, and minimize opportunity for missed billings. Upgrade or replace customer billing system for needed functionality - ensure that billing adjustments don't corrupt the value of consumption volumes. Implement procedural internal annual audit process.</p>		<p><i>To improve to 4:</i> Formalize regular review of new account activation process and general billing practices. Enhance reporting capability of computerized billing system. Formalize regular auditing process to reveal scope of data handling error. Plan for periodic third party audit to occur at least once every five years.</p>		<p><i>To improve to 5:</i> Close policy/procedure loopholes that allow some customer accounts to go unbilled, or data handling errors to exist. Ensure that billing system reports are utilized, analyzed and reported every billing cycle. Ensure that internal and third party audits are conducted at least once every three years.</p>		<p><i>To maintain a 5:</i> Stay abreast of customer information management developments and innovations. Monitor developments of Advanced Metering Infrastructure (AMI) and integrate technology to ensure that customer endpoint information is well-monitored and errors/lapses are at an economic minimum.</p>	Not a choice	
Line 26 Unauthorized consumption	<p><i>Current condition:</i> Extent of unauthorized consumption is unknown due to unclear policies and poor recordkeeping. Total unauthorized consumption is estimated.</p>	<p><i>Current condition:</i> Unauthorized consumption is a known occurrence, but its extent is a mystery. There are no requirements to document observed events, but periodic field reports capture some of these occurrences. Total unauthorized consumption is approximated from this limited data.</p>	<p><i>Conditions between 1 and 2</i></p>	<p><i>Current condition:</i> Procedures exist to document some unauthorized consumption such as observed unauthorized fire hydrant openings. Use formulae to quantify this consumption (time running multiplied typical flowrate, multiplied by number of events).</p>	<p>Default value of 0.25% of volume of billed authorized water is employed.</p>	<p><i>Current condition:</i> Coherent policies exist for some forms of unauthorized consumption (more than simply fire hydrant misuse) but others await closer evaluation. Reasonable surveillance and recordkeeping exist for occurrences that fall under the policy. Volumes quantified by inference from these records.</p>	<p><i>Conditions between 3 and 4</i></p>	<p><i>Current condition:</i> Clear policies and good auditable recordkeeping exist for certain events (ex: tampering with water meters, illegal bypasses of customer meters); but other occurrences have limited oversight. Total consumption is a combination of volumes from formulae (time x typical flow) and subjective estimates of unconfirmed consumption.</p>	<p><i>Conditions between 4 and 5</i></p>	<p><i>Current condition:</i> Clear policies exist to identify all known unauthorized uses of water. Staff and procedures exist to provide enforcement of policies and detect violations. Each occurrence is recorded and quantified via formulae (estimated time running multiplied by typical flow) or similar methods. All records and calculations should exist in a form that can be audited by a third party.</p>	Not a choice	

Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
Component	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
APPARENT LOSSES											
<i>Improvements in quantifying volume of unauthorized consumption</i>	<p><i>To improve to 2.5:</i> Use accepted default of 0.25% of billed authorized.</p> <p><i>To improve to 1:</i> Review utility policy regarding what water uses are considered unauthorized, and consider tracking a small sample of one such occurrence (ex: unauthorized fire hydrant openings).</p>	<p><i>To improve to 2.5:</i> Use accepted default of 0.25% of billed authorized.</p> <p><i>To improve to 2:</i> Review utility policy regarding what water uses are considered unauthorized, and consider tracking a small sample of one such occurrence (ex: unauthorized fire hydrant openings).</p>		<p><i>To improve to 2.5:</i> Utilize accepted default value of 0.25% of billed authorized as an expedient means to gain a reasonable quantification of all such use. This is particularly appropriate for water utilities who are in the early stages of the water auditing process.</p>	<p><i>To improve to 3:</i> Finalize policy updates to clearly identify the types of water consumption that are authorized from those usages that fall outside of this policy and are, therefore, unauthorized. Begin to conduct regular field checks. Proceed if the top-down audit already exists and/or a great volume of such use is suspected.</p>	<p><i>To improve to 4:</i> Assess water utility policies to ensure that all known occurrences of unauthorized consumption are outlawed, and that appropriate penalties are prescribed. Create written procedures for detection and documentation of various occurrences of unauthorized consumption as they are uncovered.</p>		<p><i>To improve to 5:</i> Refine written procedures and assign staff to seek out likely occurrences of unauthorized consumption. Explore new locking devices, monitors and other technologies designed to detect and thwart unauthorized consumption.</p>		<p><i>To maintain a 5:</i> Continue to refine policy and procedures to eliminate any loopholes that allow or tacitly encourage unauthorized consumption. Continue to be vigilant in detection, documentation and enforcement efforts.</p>	Not a choice
REAL LOSSES											
<i>Line 28 Reported breaks and leaks</i>	<p><i>Current condition:</i> Arbitrary estimates of reported breaks and leaks repaired. Repairs of reported breaks and leaks not documented.</p>	<p><i>Current condition:</i> Reported breaks and leaks estimated by repair crew is suspect. No written procedures exist for estimating or documenting breaks and leaks.</p>	<p><i>Conditions between 1 and 2</i></p>	<p><i>Current condition:</i> Reported breaks and leaks are estimated by repair crew. Written procedures exist for estimating or documenting breaks and leaks.</p>	<p><i>Conditions between 2 and 3</i></p>	<p><i>Current condition:</i> Breaks and leaks reported by customers and city staff fixed <75% of time. Call-to-repair times known, but are greater than one week average. Good records of breaks and leaks exist.</p>	<p><i>Conditions between 3 and 4</i></p>	<p><i>Current condition:</i> Breaks and leaks reported by customers and city staff fixed >75% of time. Call-to-repair times average less than one week. Computerized maintenance management system is used to document leak repair trends.</p>	<p><i>Conditions between 4 and 5</i></p>	<p><i>Current condition:</i> Breaks and leaks reported by customers and city staff fixed >90% of time. Call-to-repair times average less than three days. Outstanding computer maintenance records track system deficiencies and repair crew performance.</p>	Not a choice
<i>Improvements in quantifying reported breaks and leaks</i>	<p><i>To improve to 1:</i> Document reported breaks and leaks. Use leak rates calculation to estimate volume lost from reported breaks and leaks.</p>	<p><i>To improve to 2:</i> Develop standards to find, repair, and document leaks and breaks. Continue to use of leak rates calculation to estimate volume lost from reported breaks and leaks.</p>		<p><i>To improve to 3:</i> Standardize recordkeeping of leak incidents, location, response time, and other repair data.</p>	<p><i>To improve to 4:</i> Continue to standardize recordkeeping process. Begin planning a computerized maintenance management system. Reduce average leak run time to less than one week.</p>		<p><i>To improve to 5:</i> Implement computerized maintenance management system to document repairs. Reduce average leak run time to less than two days. Begin planning a proactive leak detection program.</p>		<p><i>To maintain a 5:</i> Use capabilities of computerized maintenance management system to track failure trends in distribution system and repair crew activity costs. Conduct a proactive leak detection program.</p>	Not a choice	

Assessment Scale Table Adapted from American Water Works Association Free Water Audit Software©											
Component	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
REAL LOSSES											
<i>Line 29 Unreported losses</i>	<i>Current condition:</i> Utility does not conduct any leak detection using leak detection equipment. Leak detection only includes visible leak detection (reported breaks and leaks).	<i>Current condition:</i> Limited leak detection using basic sounding performed for a portion of the distribution system. No records of leak detection exist.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Proactive leak detection using basic sounding. Simple leak detection records exist.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Proactive leak detection using basic sounding and correlation. Detailed leak detection records exist. Utility has one or more District Metered Areas.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Proactive leak detection using basic sounding, correlation, and flow monitoring. Detailed leak detection and asset condition records exist. A detailed real loss component analysis has been conducted.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Fully integrated flow monitoring and leak detection program with continuous reporting and analysis of system leakage. Utility has integrated their leak detection program with their asset management and GIS databases. An economic level of leakage assessment has been conducted.	Not a choice
<i>Improvements in quantifying unreported losses</i>	<i>To improve to 1:</i> Incorporate leak detection using basic sounding equipment.	<i>To improve to 2:</i> Plan proactive leak detection. Set a structured leak survey schedule. Keep records of leak detection program.		<i>To improve to 3:</i> Upgrade leak detection capabilities using electronic correlation. Improve the detail of records. Evaluate the feasibility of continuous flow monitoring in one or more District Metered Areas.		<i>To improve to 4:</i> Improve leak detection and flow monitoring capabilities. Improve records by including an analysis of asset conditions. Conduct a real loss component analysis.		<i>To improve to 5:</i> Fully integrate flow monitoring and leak detection and continuously report and analyze leakage data. Integrate leak detection with asset management and GIS databases. Conduct an economic level of leakage assessment.		<i>To maintain a 5:</i> Continue to standardize and audit on a regular basis.	Not a choice
COST DATA											
<i>Line 40 Customer retail price of water (applied to apparent losses)</i>	<i>Current condition:</i> Antiquated, cumbersome water rate structure is used, with periodic historic amendments that were poorly documented and implemented; resulting in classes of customers being billed inconsistent charges. The actual composite billing rate likely differs significantly from the published water rate structure, but a lack of auditing leaves the degree of error indeterminate.	<i>Current condition:</i> Dated, cumbersome water rate structure, not always employed consistently in actual billing operations. The actual composite billing rate is known to differ from the published water rate structure, and a reasonably accurate estimate of the degree of error is determined, allowing a composite billing rate to be quantified.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Straight-forward water rate structure in use, but not updated in several years. Billing operations reliably employ the rate structure. The composite billing rate is derived from a single customer class such as residential customer accounts, neglecting the effect of different rates from varying customer classes.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Clearly written, up-to-date water rate structure is in force and is applied reliably in billing operations. Composite customer rate is determined using a weighted average residential rate using volumes of water in each rate block.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Effective water rate structure is in force and is applied reliably in billing operations. Composite customer rate is determined using a weighted average composite consumption rate, which includes residential, commercial, industrial, institutional (CII), and any other distinct customer classes within the water rate structure.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Current, effective water rate structure is in force and applied reliably in billing operations. The rate structure and calculations of composite rate - which includes residential, commercial, industrial, institutional (CII), and other distinct customer classes - are reviewed by a third party knowledgeable in the M36 methodology at least once every five years.	Not a choice
<i>Improvements in quantifying the retail price of water</i>	<i>To improve to 1:</i> Formalize the process to implement water rates, including a secure documentation procedure. Create a current, formal water rate document and gain approval from all stakeholders.	<i>To improve to 2:</i> Review the water rate structure and update/formalize as needed. Assess billing operations to ensure that actual billing operations incorporate the established water rate structure.		<i>To improve to 3:</i> Evaluate volume of water used in each usage block by residential users. Multiply volumes by full rate structure.		<i>To improve to 4:</i> Evaluate volume of water used in each usage block by all classifications of users. Multiply volumes by full rate structure.		<i>To improve to 5:</i> Conduct a periodic third-party audit of water used in each usage block by all classifications of users. Multiply volumes by full rate structure.		<i>To maintain a 5:</i> Keep water rate structure current in addressing the water utility's revenue needs. Update the calculation of the customer unit rate as new rate components, customer classes, or other components are modified.	Not a choice

Component	Assessment Scale Table										
	Adapted from American Water Works Association Free Water Audit Software©										
COST DATA	0.5	1	1.5	2	2.5	3	3.5	4	4.5	5	N/A
Line 43 Variable production cost (applied to real losses)	<i>Current condition:</i> Incomplete paper records and lack of documentation on primary operating functions (electric power and treatment costs most importantly) makes calculation of variable production costs a pure estimated.	<i>Current condition:</i> Reasonably maintained, but incomplete, paper or electronic accounting provides data to roughly estimate the basic operations costs (pumping power costs and treatment costs) and calculate a unit variable production cost.	<i>Conditions between 1 and 2</i>	<i>Current condition:</i> Electronic, industry-standard cost accounting system in place. Electric power and treatment costs are reliably tracked and allow accurate weighted calculation of unit variable production costs based on these two inputs and water imported purchase costs (if applicable). All costs are audited internally on a periodic basis.	<i>Conditions between 2 and 3</i>	<i>Current condition:</i> Reliable electronic, industry-standard cost accounting system in place, with all pertinent water system operating costs tracked. Pertinent additional costs beyond power, treatment and water imported purchase costs (if applicable) such as liability, residuals management, wear and tear on equipment, impending expansion of supply, are included in the unit variable production cost, as applicable. The data is audited at least annually by utility personnel.	<i>Conditions between 3 and 4</i>	<i>Current condition:</i> Reliable electronic, industry-standard cost accounting system in place, with all pertinent primary and secondary variable production and water imported purchase (if applicable) costs tracked. The data is audited at least annually by utility personnel, and at least once every three years by a third-party knowledgeable in the M36 methodology.	<i>Conditions between 4 and 5</i>	<i>Current condition:</i> Either of two conditions can be met to obtain a grading of 10: 1) Third party CPA audit of all pertinent primary and secondary variable production and water imported purchase (if applicable) costs on an annual basis. or: 2) Water supply is entirely purchased as bulk water imported, and the unit purchase cost - including all applicable marginal supply costs - serves as the variable production cost. If all applicable marginal supply costs are not included in this figure, a grade of 10 should not be selected.	Not a choice
Improvements in quantifying the variable production cost	<i>To improve to 1:</i> Gather available records, institute new procedures to regularly collect and audit basic cost data and most important operations functions.	<i>To improve to 2:</i> Implement an electronic cost accounting system, structured according to accounting standards for water utilities.	<i>To improve to 3:</i> Formalize process for regular internal audits of production costs. Assess whether additional costs (liability, residuals management, equipment wear, and impending infrastructure expansion) should be included to calculate a more representative variable production cost.	<i>To improve to 4:</i> Formalize the accounting process to include direct cost components (power, treatment) as well as indirect cost components (liability, residuals management, etc.) Arrange to conduct audits by a knowledgeable third-party at least once every three years.	<i>To improve to 5:</i> Standardize the process to conduct a third-party financial audit by a CPA on an annual basis.	<i>To maintain a 5:</i> Maintain program, stay abreast of expenses subject to erratic cost changes and budget/track costs proactively.	Not a choice				
Total Score Possible											100